NON-CORE ISSUES

Facility	License #	Physical Address	Phone Number
Meadows Assisted Living Center	RC-1002	16 Airport Road	208-756-1043
Administrator	City	Zip Code	Survey Date
Michelle Bingham	Salmon	83467	11/30/2021
Survey Team Leader	Survey Type		Response Due
Chaney, Linda	Fire Life Safety and Sanitation Licensure		12/30/2021

Item #	Rule (16.03.22)	Description
1	.403. FIRE AND LIFE SAFETY STANDARDS FOR EXISTING BUILDINGS LICENSED FOR THREE THROUGH SIXTEEN RESIDENTS.	Facility did not maintain compliance with the 2018 edition of NFPA 101, Life Safety Code, Chapter 33, Existing Residential Board and Care Occupancies, Small Facilities as evidenced by the following: 1.) Facility could not produce documentation for an annual inspection of the fire alarm system.(NFPA 72, 14.3.1) - 2.) No documentation could be produced for a 5-year assessment of the internal condition of the sprinkler system piping; to include the calibration or replacement of system gauges (NFPA 25, 14.2.1.1) 3.) No documentation could be produced to show staff are trained periodically on safety guidelines, usage requirements and the risks associated with the handling and use of oxygen. (NFPA 99, 11.5.2.1)