NON-CORE ISSUES

Facility	License #	Physical Address	Phone Number
Elegant Residential Living	RC-1202	1256 Wright Ave	208-478-9400
Administrator	City	Zip Code	Survey Date
Jodie Katsilometes	Pocatello	83202	07/26/2022
Survey Team Leader	Survey Type		Response Due
Chaney, Linda	Fire Life Safety and Sanitation Licensure		08/25/2022

Item #	Rule (16.03.22)	Description
1	.403. FIRE AND LIFE SAFETY STANDARDS FOR EXISTING BUILDINGS LICENSED FOR THREE THROUGH SIXTEEN RESIDENTS.	The facility did not maintain compliance with the 2018 edition of NFPA 101, Life Safety Code, Chapter 33, Existing Residential Board and Care Occupancies, Small Facilities as evidenced by the following: 1.) One Smoke Detector in building two (2) was replaced on May 22, 2021. The facility could not produce documentation to show sensitivity testing had been performed at one year from installation.(NFPA 72, 14.4.4.3.1)
2	.250.10.b. Heating, Ventilation, and Air-Conditioning (HVAC).	Each building, #1 - #4 had a natural gas fireplace in the living area. None of the gas fireplaces were equipped with a safety barrier.