NON-CORE ISSUES

Facility	License #	Physical Address	Phone Number
Antelope Creek Living Center	RC-514	3668 W 3700 N	208-588-2700
Administrator	City	Zip Code	Survey Date
Cindy Smith	Darlington	83255	08/29/2022
Survey Team Leader	Survey Type		Response Due
Burbank, Sam	Fire Life Safety and Sanitation Licensure		09/28/2022

Item #	Rule (16.03.22)	Description
1	.161. SMOKING REQUIREMENTS.	Designated smoking areas for both staff and residents are not clearly marked or identified.
2	.250.12.j. Resident Sleeping Rooms.	Resident sleeping rooms shall be provided with doors that resist the passage of smoke: Room 40 on the second floor was not equipped with a door.
3	.404. FIRE AND LIFE SAFETY STANDARDS FOR EXISTING BUILDINGS LICENSED FOR SEVENTEEN OR MORE RESIDENTS AND MULTI-STORY BUILDINGS.	1) No documented review of the emergency action plan by staff conducted bimonthly in accordance with NFPA 101, Chapter 33, Section 33.7.1.3. (Repeat) 2) UL 300 hood fire suppression systems shall be inspected and tested not more than six months apart in accordance with NFPA 96, Chapter 11, Section 11.2.1: Fire suppression system inspections for the UL 300 hood were eight months apart, 10/8/21 and 6/1/22. 3) Fire suppression system pendants shall be maintained in accordance with NFPA 25, Chapter 5, Section 5.2.1.1.1: Bathrooms A and C, upright pendant is corroded; Room 40 upright pendant has non-factory applied paint. All suppression system pendants showing these conditions shall be replaced. 4) Emergency action plan does not specify a designated point of assembly as outlined in NFPA 101, Chapter 33, Section 33.7.3.3.

4	.405.01. Electrical Installations and Equipment.	Open electrical connections with exposed wiring shall be covered in accordance with NFPA 70, Article 110, Section 110.27: Chemical closet had a 3 inch diameter junction box without a protective cover over the live wiring. (repeat - cited previously on breaker open with live wiring)
5	.405.02.c. Prohibited Applications.	Relocatable power taps (RPTs) are prohibited with the use of appliances: Staff room on the west side using a RPT for a microwave and mini-fridge; Sitting room using RPT for A/C unit.
6	.410. REQUIREMENTS FOR EMERGENCY ACTIONS AND FIRE DRILLS.	Emergency egress and relocation drills shall be conducted in accordance with NFPA 101, Chapter 33, Section 33.7.3.3; evacuated to a designated point of assembly as outlined int he emergency action plan. Drill conducted did not document to what area the residents evacuated and the EAP did not specify the designated point of assembly.