NON-CORE ISSUES

Facility	License #	Physical Address	Phone Number
Autumn Haven Assisted Living, Inc.	RC-1256	924 Christian Way	208-436-3200
Administrator	City	Zip Code	Survey Date
Angie Darrington	Rupert	83350	09/22/2022
Survey Team Leader	Survey Type		Response Due
Chaney, Linda	Fire Life Safety and Sanitation Licensure		10/22/2022

Item #	Rule (16.03.22)	Description
1	.410. REQUIREMENTS FOR EMERGENCY ACTIONS AND FIRE DRILLS.	Emergency egress and relocation drills are required not less than six (6) times a year on a bimonthly basis. The facility failed to perform drills bimonthly. At the time of the survey, drills had been performed in March, May, and June of 2022; September and December 2021. There was no other documentation available at the time of survey.
2	.250.10.b. Heating, Ventilation, and Air-Conditioning (HVAC).	During the facility tour, observation of the natural gas fireplace in the living area of the facility revealed the screen provided did not prevent the glass on the front of the fireplace from being touched. When tested, the screen easily pressed up against the glass. There was no other safety barrier present.