NON-CORE ISSUES

Facility	License #	Physical Address	Phone Number
Apple Valley Residence	RC-1199	715 North Butte Avenue	208 365 1497
Administrator	City	Zip Code	Survey Date
Dawn Brotherson	Emmett	83617	11/09/2022
Survey Team Leader	Survey Type		Response Due
Burbank, Sam	Fire Life Safety and Sanitation Licensure		12/09/2022

Item #	Rule (16.03.22)	Description
1	.404. FIRE AND LIFE SAFETY STANDARDS FOR EXISTING BUILDINGS LICENSED FOR SEVENTEEN OR MORE RESIDENTS AND MULTI-STORY BUILDINGS.	1) Only one of three quarterly waterflow alarm testing. Waterflow alarm testing shall be conducted not less than quarterly in accordance with NFPA 25, Chapter 5, Section 5.3.2.1. 2) Only one documented semi-annual hood cleaning from October of 2021 and hood fire suppression from October of 2021. UL 300 hood systems shall be serviced and tested in accordance with NFPA 17A, Chapter 7, Section 7.3.2 and NFPA 96, Chapter 11, Section 11.4
2	.405.02.c. Prohibited Applications.	Relocatable power taps (RPTs) are prohibited for use with appliances: Kitchen using RPT to supply power to a microwave. (corrected 11/9/22)
3	.410. REQUIREMENTS FOR EMERGENCY ACTIONS AND FIRE DRILLS.	Only three of six documented emergency egress and relocation drills. Emergency egress and relocation drills shall be conducted not less than six times per year with not less than two conducted on the night shift when residents are normally asleep.