NON-CORE ISSUES

Facility	License #	Physical Address	Phone Number
Whispering Pines Assisted Living Center	RC-1229	351 E Center St	208-897-5683
Administrator	City	Zip Code	Survey Date
Brie Moore	Downey	83234	06/07/2023
Survey Team Leader	Survey Type		Response Due
Burbank, Sam	Fire Life Safety Non-Core Follow-Up		07/07/2023

Item #	Rule (16.03.22)	Description
1	.403. FIRE AND LIFE SAFETY STANDARDS FOR EXISTING BUILDINGS LICENSED FOR THREE THROUGH SIXTEEN RESIDENTS.	Facility cooking operations are not provided with an operational hood system in accordance with NFPA 101, Chapter 33, Section 33.3.3.8. Cited by Fire Life and Safety on 12/5/22; Health survey of 4/13/23 and this survey. Three-peat citation.