NON-CORE ISSUES

Facility	License #	Physical Address	Phone Number
BeeWell Assisted Living Winterberry, LLC	RC-1245	3989 E Winterberry Dr	(208) 957-7506
Administrator	City	Zip Code	Survey Date
Melissa Rodriguez	Nampa	83687	01/22/2024
Survey Team Leader	Survey Type		Response Due
Wilson, Jeremy	Fire Life Safety and Sanitation Licensure		02/21/2024

Item #	Rule (16.03.22)	Description
1	.403. FIRE AND LIFE SAFETY STANDARDS FOR EXISTING BUILDINGS LICENSED FOR THREE THROUGH SIXTEEN RESIDENTS.	REPEAT: Facility failed to provide documentation for a 5-year sensitivity test of the smoke detectors. When asked the Administrator stated she was unaware this had not been completed and called the vendor. Vendor stated this was an inspection they had not performed since taking over in 2021.
2	.405.01.a. Electrical Installations and Equipment.	During facility tour conducted on January 22, 2024, Observation of Room 8 established an extension cord plugged into a wall outlet running across the floor plugged into a television.
3	.405.02.c. Prohibited Applications.	During facility tour conducted on January 22, 2024, Observation of Room 8 established an Ice maker plugged into an RPT.