NON-CORE ISSUES

Facility	License #	Physical Address	Phone Number
Meadow Lake Village Retirement Resort - Owyhee Bldg	RC-1048	590 South Arbor Lane	208-888-2277
Administrator	City	Zip Code	Survey Date
Cassidy Fenton	Meridian	83642	06/20/2024
Survey Team Leader	Survey Type		Response Due
McClenathan, Teresa	Health Care Licensure and Follow-Up		07/20/2024

Item #	Rule (16.03.22)	Description
1	.250.09. Resident Sleeping Rooms.	The facility's hot water temperatures were not consistently maintained between 105 and 120 degrees F. For example, the water temperatures taken in multiple resident rooms in Oak and Elm units at 130 to 140 degrees F on 6/18/24. The administrator stated they were unaware the water temperatures were out of range.