NON-CORE ISSUES

Facility	License #	Physical Address	Phone Number
Bluebonnet Haus	RC-1253	641 Rimview	208-734-4445
Administrator	City	Zip Code	Survey Date
Betty Bennett	Twin Falls	83301	11/04/2024
Survey Team Leader	Survey Type		Response Due
Wilson, Jeremy	Fire Life Safety and Sanitation Licensure		12/04/2024

Item #	Rule (16.03.22)	Description
1	.330.15. Fire and Life Safety Records.	The administrator must ensure the facility's records for fire and life safety are maintained. The facility must maintain on file: 1. Facility was unable to provide documentation for annual inspections and testing of portable fire extinguishers. 2. Facility was unable to provide documentation for semi-annual inspection and testing of Vane-type fire suppression system waterflow alarm devices.
2	.403. FIRE AND LIFE SAFETY STANDARDS FOR EXISTING BUILDINGS LICENSED FOR THREE THROUGH SIXTEEN RESIDENTS.	Facility did not maintain compliance with the 2018 edition of NFPA 101, Life Safety Code, Chapter 33, Existing Residential Board and Care Occupancies, Small facilities as evidenced by the following: 1. ***Previously cited 6/30/2022*** The facility was unable to produce any documentation for the testing of emergency lighting; 30 seconds monthly and 90 minutes annually, in accordance with NFPA 101, Chapter 7, Section 7.9.3.1.1. ***end of previous citation*** 2. Facility failed to maintain emergency lighting in accordance with NFPA 101, Chapter 7, Section 7.9.2.3 and 7.9.2.7. During facility tour it was identified the battery-operated emergency light located in the dining room next to the rear exit door was inoperable based on functional testing.
3	.410. REQUIREMENTS FOR EMERGENCY ACTIONS AND FIRE	*** Previously cited 6/30/2022*** Emergency egress and

	DRILLS.	relocation drills are required not less than (6) times a year on a bimonthly basis. The facility failed to perform drills bimonthly. At the time of the survey, drills had been performed in September 2023, November 2023, February 2024, April 2024 and the last documented drill was July 2024.