NON-CORE ISSUES

Facility	License #	Physical Address	Phone Number
Antelope Creek Living Center	RC-514	3668 W 3700 N	208-588-2700
Administrator	City	Zip Code	Survey Date
Tiffanee Henson	Darlington	83255	12/18/2024
Survey Team Leader	Survey Type		Response Due
Wilson, Jeremy	Fire Life Safety and Sanitation Licensure		01/17/2025

Item #	Rule (16.03.22)	Description
1	.161.04. Designated Smoking Areas.	***Previously cited 8/29/2022 under rule 161*** Designated smoking area for residents and staff was not clearly marked or identified.
2	.403. FIRE AND LIFE SAFETY STANDARDS FOR EXISTING BUILDINGS LICENSED FOR THREE THROUGH SIXTEEN RESIDENTS.	1. Gauges monitoring air or nitrogen pressure shall be inspected monthly to verify that normal air or nitrogen pressure are being maintained, in accordance with NFPA 25, Chapter 13, Section 13.2.7.1.3. Facility could not provide documentation for the monthly inspection of air gauges of the dry pipe fire suppression system. 2. Facility fire alarm inspection documentation failed to list the locations of all initiating/ detection devices that were tested, including but not limited to: smoke detectors, manual pull stations, horn strobes and magnetic door releases, in accordance with NFPA 72, Chapter 7, Section 7.6.6.
3	.410. REQUIREMENTS FOR EMERGENCY ACTIONS AND FIRE DRILLS.	Emergency egress drills shall be conducted not less than six times per year on a bi-monthly basis. Facility provided documentation of drills identified the last drill was conducted in September 2024, with a gap from June 2024 to September 2024, all drills were conducted on NOC shift needing to go back to January 2024 to find a day shift drill. With a total of 5 documented drills since August 2023.