NON-CORE ISSUES

Facility	License #	Physical Address	Phone Number
Ashley Manor Middleton DBA Middleton Senior Living LLC	RC-843	620 West 9th Street North	208-585-2310
Administrator	City	Zip Code	Survey Date
Nina Hutton	Middleton	83644	01/30/2025
Survey Team Leader	Survey Type		Response Due
Hoover, Shaun	Fire Life Safety and Sanitation Licensure		03/01/2025

Item #	Rule (16.03.22)	Description
1	.403. FIRE AND LIFE SAFETY STANDARDS FOR EXISTING BUILDINGS LICENSED FOR THREE THROUGH SIXTEEN RESIDENTS.	1.) ***REPEAT. Previously cited on 02/24/2023*** The facility was unable to produce documentation for the testing of emergency lighting 30-second monthly and 90-minute annually in the past 12 months. (NFPA 101, 7.9.3.1.1). 2.) The emergency lights on the Exit sign located above the front door did not operate when tested.
2	.410. REQUIREMENTS FOR EMERGENCY ACTIONS AND FIRE DRILLS.	***Repeat, last repeat 02/24/2023.***Emergency egress and relocation drills are required not less than six (6) times a year on a bi-monthly basis with at least two (2) drills conducted at night when the residents are sleeping. The facility failed to produce drills conducted on a bi-monthly basis, or at night when the residents were sleeping.