NON-CORE ISSUES

Facility	License #	Physical Address	Phone Number
Gables of Pocatello Assisted Living	RC-1062	2805 South Grant Avenue	208-232-1091
Administrator	City	Zip Code	Survey Date
Joyce Foster	Pocatello	83204	03/05/2025
Survey Team Leader	Survey Type		Response Due
Wilson, Jeremy	Fire Life Safety and Sanitation Licensure		04/04/2025

Item #	Rule (16.03.22)	Description
1	.405.01.a. Electrical Installations and Equipment.	During facility tour it was identified in room #1, a CPAP and an Oxygen concentrator plugged into a multi-plug adapter, in room #15 it was identified a television, charging device and an electronic photo frame plugged into a multi-plug adapter. The use of multi-plug adapters is prohibited.
2	.410. REQUIREMENTS FOR EMERGENCY ACTIONS AND FIRE DRILLS.	During record review it was identified the seven (7) conducted emergency egress/ fire drills held between 1/16/2024 to 1/29/2025 were all conducted between 1:30 and 3:30 PM, not meeting the requirement of at least two (2) being conducted during the night when residents are sleeping.
3	.250.10.b. Heating, Ventilation, and Air-Conditioning (HVAC).	During facility tour it was identified the gas-fired fireplace located in the main living room area was equipped with the heat-tempered glass cover but did not have a provided safety barrier as required. All fireplaces must provide a safety barrier and have heat-tempered glass fireplace enclosures equivalent to ASTM Standard.