NON-CORE ISSUES

Facility	License #	Physical Address	Phone Number
Touchmark at Meadowlake Village	RC-894	650 South Arbor Lane	208-319-5400
Administrator	City	Zip Code	Survey Date
Carly Verkuehlen	Meridian	83642	05/29/2026
Survey Team Leader	Survey Type		Response Due
Bollinger, Torrey	Health Care Licensure and Follow-Up		06/28/2026

Item #	Rule (16.03.22)	Description
1	.161.01. Combustible Supplies and Flammable Items.	The facility did not ensure the staff smoking area was in an area away from where combustible supplies or materials, including flammable liquids, gases, or oxidizers are in use or stored. For example, between 5/28/26 and 5/29/26, staff were observed to be smoking in a designated area between two propane tanks and a large diesel generator. The facility administrator stated the designated area would be relocated.