NON-CORE ISSUES

Facility	License #	Physical Address	Phone Number
Edgewood Spring Creek Overland, LLC	RC-1009	10139 West Overland Road	208-639-7000
Administrator	City	Zip Code	Survey Date
Gary Weaver	Boise	83709	06/11/2026
Survey Team Leader	Survey Type		Response Due
Bollinger, Torrey	Health Care Licensure and Follow-Up		07/11/2026

Item #	Rule (16.03.22)	Description
1	.161.04. Designated Smoking Areas.	During facility tour it was identified the smoking area in back of the facility was not clearly marked and/ or established within policy as the designated smoking area. The administrator confirmed the smoking area did not have signage and was not clearly marked.
6	.404. FIRE AND LIFE SAFETY STANDARDS FOR EXISTING BUILDINGS LICENSED FOR SEVENTEEN OR MORE RESIDENTS AND MULTI-STORY BUILDINGS.	The facility's last fire alarm sensitivity test was on 3/16/2021, this resulted in a gap of more than 5 years. The administrator confirmed the inspection had not been completed. ***Previously cited on 7/24/23***
6	.405.01.a. Electrical Installations and Equipment.	During the facility tour, two Multi-Plug Adapters (MPA) were observed in use in room 37B. ***Previously cited on 7/24/23***
7	.310.01.g. Medication Distribution System.	Resident #3 did not have their as-needed (PRN) hydrocodone-acetaminophen and mucus relief available. Resident #10 did not have their PRN olanzapine and stomach relief available. The facility RN stated the medications were not available due to the facility changing pharmacies.
8	.405.04. Prohibited Applications.	The facility had two gas fireplaces, one located in the main sitting area and the other in the library of the facility. The fuel fired heating inspection/testing did not include the fireplaces

		had been inspected for safety. The administrator confirmed the fireplaces were not inspected.